



385-2019 ADDENDUM 1

SHOAL LAKE AQUEDUCT – SUPPLY AND INSTALLATION OF STOP LOGS

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: May 9, 2019
BY: Jordan Thompson, P. Eng.
TELEPHONE NO. 204 928-9222

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E7.4.2 to read: Manufacturers:

- (a) ISE Fontaine Aquanox.
- (b) Hydro Gate.
- (c) RW Gate Company.
- (d) Or approved equal in accordance with B7.

Revise: E7.4.3 (b) to read: Stop log configuration, dimensions and characteristics: As shown on drawings and as specified herein. Frame mounting configurations alternative to the one shown on the drawings will be acceptable. The total width of the entire stop log assembly including frame and stop log cannot exceed the existing width of the existing stop log groove.

APPENDICES

Replace: 385-2019_Appendix_C with the attached 385-2019_Addendum_1-Appendix_C. Appendix has been updated with additional photos of the general layout of the Mile 64.14 site.