



**INCONSISTENCIES:**  
 I-1 DCS ANALOG OUTPUTS DBD638TC1 & DBD638TC2 ARE NOT CURRENTLY DESIGNATED CORRECTLY IN THE DCS SOFTWARE  
 I-2 SOME EXISTING DOCUMENTATION AND LABELLING MAY REFER TO D513-DF13 RATHER THAN D613-DF13.

**CONSTRUCTION NOTES:**  
 ① INSTALL INTERLOCK TO START FAN UPON GAS DETECTION ALARM.

REVISION 04  
 THE ENGINEER'S DESIGN RESPONSIBILITIES ARE LIMITED TO THE CHANGES INDICATED IN THE CLOUDED WORK

DESIGNED BY: C. REIMER	CHECKED BY: C. REIMER
DRAWN BY: C. REIMER	APPROVED BY: C. REIMER
DATE: 2019-08-01	



B.M. ELEV.	FIELD BOOK #:
POSTED TO LBIS	
DESIGNED BY: EXISTING	CHECKED BY: CJR
DRAWN BY: CJR	APPROVED BY: EMR
04 ISSUED FOR CONSTRUCTION	2019-08-01 CJR
03 ORIG # WAS 1-0101D-G-A0257-001-02D.dwg	2010/12/07 SPH
01 ISSUED FOR C.O.W. USE	2005/09/15 CJR
00 RELEASED FOR CUSTOMER REVIEW	2005/08/22 CJR
NO. REVISIONS	DATE BY FILENAME:

SNC • LAVALIN Engineers & Constructors		SNC • LAVALIN 200-1600 Ness Avenue Winnipeg, Manitoba Canada R3J 3W7	
DESIGNED BY: EXISTING		CHECKED BY: CJR	
DRAWN BY: CJR		APPROVED BY: EMR	
HOR. SCALE: NTS		RELEASED FOR CONSTRUCTION	
DATE: 2005/02/22		DATE:	
ENGINEER'S SEAL			
BID OPPORTUNITY NO. 630-2019			

THE CITY OF WINNIPEG  
 WATER AND WASTE DEPARTMENT

NORTH END WATER POLLUTION CONTROL CENTRE  
 DIGESTERS  
 PROCESS & INSTRUMENT DIAGRAM  
 DIGESTER EAST GAS ROOM HVAC

CITY DRAWING NUMBER: 1-0101D-A0071  
 SHEET: 001  
 REV.: 04  
 SIZE: SHEET

1-0101D-A0112	GAS DETECTION AND ALARMING, EAST GAS ROOM
1-0101A-A0001	PROCESS AND INSTRUMENT DIAGRAMS LEGEND AND DETAILS
DRAWING NUMBER	REFERENCE DRAWINGS