



NOTE: STRUCTURAL DESIGN OF PROPOSED SHELTER BUILDING, AND FOUNDATIONS SATISFIES THE MANITOBA BUILDING CODE 2011.

NOTE: IN ORDER TO AVOID CONDUIT INTERFERENCE WITH PILE, MOVE GENERATOR #150mm WITH RESPECT TO THE CENTRE OF FOUNDATION.

A	DRAWING UPDATE	07/11/16	JSG
ISSUE	DESCRIPTION	DATE	BY
TITLE: GENERATOR PAD FOUNDATION			



CUSTOMER: CITY OF WINNIPEG
 PROJECT: SITE UPGRADE
 SITE: 2230 MAIN STREET, WINNIPEG, MB
 DRAWN BY/APP'D: JSG
 DATE: 19/10/16
 PROJECT No.: 22-00243
 DRAWING No.: -E04

ELEVATION VIEW