


## NOTES

- 1. ELECTRICAL DESIGN IS BASED ON PSECO INC. EQUIPMENT AND EQUIPMENT ELECTRICAL REQUIREMENTS. CONTRACTOR RESPONSIBLE FOR DESIGN CHANGES REQUIRED BASED ON BUS WASH EQUIPMENT MANUFACTURER / SUPPLIER.
- REFER TO PSECO INC. SHOP DRAWINGS FOR BRANCH CIRCUITING TO MOTORS AND 2 CONTROL DEVICES. ALL ELECTRICAL WIRING, CONDUIT, CONNECTIONS TO MEET CEC-1-2018.
- 3. ALL CONNECTORS AND CONDUIT FITTINGS TO BE WATERTIGHT. ALL CONDUIT AND CABLE CONNECTIONS TO PANEL IN THE BUS WASH RACK AREA TO BE BOTTOM ENTRY.

DESIGNED BY APPROVED B.M. ELEV. LOCATION ENGINEER'S SEAL SCK UNDERGROUND STRUCTURES DRAWN BY SCK SUPV. U/G STRUCTURES COMMITTEE DATE CHECKED BLM BY DILLON CONSULTING NOTE: APPROVED LOCATION OF UNDERGROUND STRUCTURES AS SHOWN ARE BASED ON THE BEST INFORMATION AVAILABLE. BUT NO GUARANTEE IS GIVEN THAT ALL EXISTING UTILITIES ARE SHOWN OR THAT THE GIVEN LOCATIONS ARE EXACT. CONFIRMATION OF EXISTENCE AND EXACT LOCATION OF ALL SERVICES MUST BE OBTAINED FROM THE INDIVIDUAL UTILITIES BEFORE PROCEEDING WITH CONSTRUCTION. BY RELEASED FOR CONSTRUCTION HOR. SCALE NOTED CONSULTANT PROJECT NO. VERTICAL ISSUED FOR TENDER 20/03/27 BLM 199071 IO. REVISIONS DATE DATE 2019-02-11 DATE BY





FLOOR PLANS

E2