



- CORK INSULATION ENCAPSULATION NOTES:**
- DRAWING TO BE READ IN CONJUNCTION WITH THE TECHNICAL SPECIFICATIONS.
 - ALL EXPOSED CORK INSULATION SHALL BE COATED WITH INTUMESCENT PAINT AS PER THE SPECIFICATIONS. LOCATIONS OF EXPOSED CORK INSULATION SHOWN ON THE DRAWINGS ARE ILLUSTRATIVE ONLY AND MUST BE VERIFIED ON SITE.
 - THE EXISTING CORK PAINT COATING CONTAINS TRACE AMOUNTS OF LEAD. DO NOT SAND THE EXISTING COATING AS PART OF THE SURFACE PREPARATION PROCEDURES.
 - SURFACE PREPARE EXISTING CORK INSULATION BY SURFACE CLEANING AND DEGREASING USING NON-SOLVENT PRODUCTS.
 - MASK AREAS SUCH AS ELECTRICAL PANELS AND STRUCTURAL STEEL THAT DO NOT NEED TO BE ENCAPSULATED (NON-COMBUSTIBLES). ELECTRICAL CONDUIT MOUNTED ON THE WALLS OF PUMPING STATION CAN BE COATED WITH THE INTUMESCENT PAINT.
 - DECALS ADHERED TO CORK MUST BE REMOVED. NEW DECALS TO BE PROVIDED.
 - APPLY A SOLVENT BASED SEALER PRIMER AND ALLOW FOR FULL CURE PRIOR TO APPLICATION OF ANY INTUMESCENT PAINT.
 - APPLY ONE COAT OF FLAME CONTROL 10-10A INTUMESCENT FIRE RETARDANT PAINT OR AN APPROVED EQUAL IN ACCORDANCE WITH B7.
 - COORDINATE ANY SPECIAL VENTILATION REQUIREMENTS WITH THE CONTRACT ADMINISTRATOR AND THE CITY OF WINNIPEG.
 - COORDINATE A 2m X 2m TEST AREA WITH THE CONTRACT ADMINISTRATOR PRIOR TO PROCEEDING WITH THE WORK AS OUTLINED IN THE SPECIFICATIONS.
 - PORTIONS OF THE CORK EXTEND ABOVE THE ASBESTOS CEILING TILE. THE CONTRACTOR MUST COMPLETE THE ASBESTOS REMEDIATION PRIOR TO PAINTING OF CORK INSULATION.

10		
9		
8		
7		
6		
5		
4		
3		
2	1-0650A-D0001-001	COVER SHEET
1	1-0650M-S0008-001	STRUCTURAL - ASBESTOS REMEDIATION
NO.	DRAWING NUMBER	REFERENCE DRAWING TITLE
REFERENCE DRAWINGS		



B.M. -					
ELEV. -					
KGS GROUP		DESIGNED BY: L. MILIUS-ALPHONSE	CHECKED BY: C. SIEPMAN		
		DRAWN BY: F. VALENCIA	APPROVED BY: C. SIEPMAN		
		SCALE: AS NOTED	ISSUED FOR CONSTRUCTION BY:		
		DATE: 2019/04/30	DATE:		
0	ISSUED FOR CONSTRUCTION	2020/06/18	DATE	DESIGN CHECK	CONSULTANT NO.: 19-0107-005_S07

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT

HURST PUMPING STATION
STRUCTURAL REPAIRS AND DRAINAGE BUILDING UPGRADES
STRUCTURAL
PUMP STATION CORK INSULATION ENCAPSULATION
SECTIONS AND DETAILS

CITY DRAWING NUMBER: 1-0650M-S0007
SHEET: 001
REV: 0
SIZE: A1