ENGINEERS GEOSCIENTISTS MANITOBA Certificate of Authorization KGS Group No. 245

SUPPLY: 240V 1Ø 3W				NAME	
MAINS AMPACITY: 100					
INCOMING: 🔲 BREAKER 🗆 LUGS					
MAIN BREAKER REQUIRED: ■ YES □ NO		PANEL			
MAIN BREAKER AMPS: 60					
BUS MATERIAL: 🔳 COPPER 🗆 ALUMINUM					
BUS AND BREAKER RATING: 10kA					
REV CCT DESCRIPTION	VA	P	BKR	L1	
1 BATTERY WARMER	75	1	15	•	
3 BATTERY CHARGER	1200	1	15		
5 BLOCK HEATER	2000	2	15	•	
9 LIGHTS	—	1	15	•	
11	—	-	-		
		LOAD 'L1'			
			0		

NOTES:

1. SUPPLIED BY GENERATOR MANUFACTURER AS PART OF THE GENERATOR ENCLOSURE PACKAGE. LOAD AND BREAKER SIZES ARE SHOWN FOR INTENT ONLY; EQUIPMENT TO BE SUPPLIED AS A PERFORMANCE PACKAGE. EXACT LOAD AND WIRING REQUIREMENTS TO BE COORDINATED WITH GENERATOR SUPPLIED AS A PERFORMANCE PACKAGE. EXACT LOAD AND WIRING REQUIREMENTS TO BE COORDINATED WITH

LOCATION APPROVED UNDERGROUND STRUCTURES	B.M ELE				KGS	5			ENGINEER'S SEAL
SUPV. U/G STRUCTURES DATE					GROUP				
NOTE:					DESIGNED BY	CLS	CHECKED BY	PL	
LOCATION OF UNDERGROUND STRUCTURES AS SHOWN ARE BASED ON THE BEST INFORMATION AVAILABLE BUT NO GUARANTEE IS GIVEN THAT ALL EXISTING UTILITIES ARE SHOWN OR					DRAWN BY	SDC	APPROVED BY	CLS	
THAT ALL EXISTING OTLETTES ARE SHOWN OR THAT THE GIVEN LOCATIONS ARE EXACT. CONFIRMATION OF EXISTENCE AND EXACT LOCATION OF ALL SERVICES MUST BE					HOR. SCALE:	AS NOTED	RELEASED FO CONSTRUCTIO		
OBTAINED FROM THE INDIVIDUAL UTILITIES BEFORE PROCEEDING WITH CONSTRUCTION.	0	ISSUED FOR CONSTRUCTION	20/05/26	CLS	VERTICAL:	AS NOTED		20/05/26	CONSULTANT PROJEC
BEFORE PROCEEDING WITH CONSTRUCTION.	NO.	REVISIONS	DATE	BY	DATE	20/03/26	DATE	YY/MM/DD	20-0107-0

							1					
NAME PLATE:							LOCATION: GENERATOR ENCLOSURE					
							MOUNTING:	SURFACE	🗆 FLUSH			
PANEL 'G1 '							MANUFACTURE					
							MODEL NO:					
							BREAKER:	D PLUG-IN	BOLT-ON			
							SPD:	□ YES	NO			
							SERVICE ENTR	ANCE RATED:	□ YES	NO		
2	BKR	L1	L2	BKR	Р	VA		DESCRIPTIO	N	CCT REV		
	15	•		15	1	—	CONTROLS			2		
	15		•	- 25	2	4000	UNIT HEATER			4		
	15	•								6		
			-	15	1	_	MAINTENANCE R	RECEPTACLES		8		
<u> </u>	15	•			_	_				10		
-	-		•			—				12		
LO		_1'		DÀD 'L	2′							
	0			0								

