

58-2020 ADDENDUM 1

SUPPLY AND INSTALLATION OF FENCING BETWEEN PLAZA STATION AND CHANCELLOR DRIVE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
TENDER**

ISSUED: April 27, 2020
BY: Jesse Crowder
TELEPHONE NO. 204 986-4882

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE TENDER AND SHALL FORM A PART
OF THE CONTRACT DOCUMENTS**

Template Version: A20190115

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Tender, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

QUESTIONS AND ANSWERS

- Q1: Will the City be marking out the fence location or is that the Contractor's responsibility?
A1: The City will be marking out the fence alignment.
- Q2: Is the fence to follow the existing contours of the ground?
A2: Yes.
- Q3: Is the immediate area for the fence going to have the grass and weeds mowed by the City immediately prior to work commencing or is that the Contractor's responsibility?
A3: The immediate area is currently unfinished (rough grading is complete) but is anticipated to be topsoiled and seeded prior to the fence installation.
- Q4: Does the work area allow for access for larger trucks, skid steer loaders, etc. or is it accessible only by foot, light vehicles?
A4: The work area is only accessible from the adjacent multi-use pathway. Any damage to the pathway or adjacent area by the contractor will be repaired at the Contractor's expense.
- Q5: Is any traffic control thought to be needed for Bishop Grandin Boulevard?
A5: Traffic control on Bishop Grandin is unlikely but safety measures/traffic control on the pathway will be required if the pathway is impacted during the work.
- Q6: For working beside the train do we need special permission from CN when there are trains passing by or is the distance far enough away that that isn't a concern?
A6: Entrance onto CN property is prohibited so the distance is far enough away provided that condition is adhered to.
- Q7: Is the intent for the fence to have a bottom rail or bottom wire?
A7: The fence is to have a bottom tension wire, not a bottom rail.