



139-2021 ADDENDUM 2

PUBLIC WORKS DEPARTMENT SECURITY AND ACCESSIBILITY UPGRADES – 1155 PACIFIC AVENUE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: March 22, 2021
BY: Lou Chubenko
TELEPHONE NO. 204 470-7881

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART E – SPECIFICATIONS

DRAWINGS

Replace: 139-2021_Drawing_A1.1-R0 with 139-2021_Addendum_2_Drawing_A1.1-R1
139-2021_Drawing_A1.3-R0 with 139-2021_Addendum_2_Drawing_A1.3-R1
139-2021_Drawing_A2.0-R0 with 139-2021_Addendum_2_Drawing_A2.0-R1
139-2021_Drawing_A2.1-R0 with 139-2021_Addendum_2_Drawing_A2.1-R1

QUESTIONS AND ANSWERS

- Q1: The CPT-1 Carpet Tile description on Drawing A1.3 states to provide 3 boxes of extra material; Drawing A4.0 Specifications Section 09 68 13, Item 7.0 Maintenance states to provide 3% extra materials. How much maintenance materials do you require?
- A1: Provide minimum 3% of each type and colour of flooring products specified for project for maintenance use. Store where directed. Extra maintenance material shall be from same production run as installed material.
- Q2: Who is responsible for the Building Permit application and applicable permit fees?
- A2: Further to C6, the Contractor shall procure the Building Permit application and shall be responsible for all applicable permit fees.
- Q3: Who is responsible for supplying automatic door hardware components, as per Drawing A1.4?
- A3: The Contractor is fully responsible for supplying the door hardware components.