



NOTES :

CONSTRUCTION STANDARDS

TO BE CONSTRUCTED IN ACCORDANCE WITH MANITOBA HYDRO DISTRIBUTION AND SUBTRANSMISSION STANDARDS, LATEST REVISION. NO MAJOR CHANGE SHALL BE MADE WITHOUT APPROVAL OF THE DESIGN ENGINEER OR DELEGATE.

SURVEYS TO STAKE OUT SURVEY MONUMENTS, IF IN THE VICINITY OF THE NEW CONSTRUCTION TO PREVENT DAMAGE OR LOSS.

INSTALLED			
Quantity	Fixture Type	Wattage	Pole Type
0	LED	40	EXCLUSIVE
0	LED	150	EXCLUSIVE
0	LED	240	EXCLUSIVE
0	LED	240	SHARED

SALVAGED			
Quantity	Fixture Type	Wattage	Pole Type
0	LED	150	EXCLUSIVE
0	LED	150	SHARED
0	LED	240	EXCLUSIVE

LOCATION	LUMINAIRE	TYPE	MOUNTING HEIGHT	AVG LUX	U.R. RATIO AVG/MIN	U.R. RATIO MAX/MIN	MAX SPACING

PRELIMINARY
NOT TO BE USED FOR CONSTRUCTION

REEL NUMBER	MANUFACTURER	MANUFACTURE DATE

AUTHORITY	NOTIFIED	NOT REQ'D	OBTAINED
DEPT. OF HIGHWAYS		X	
MUNICIPAL		X	
M.T.S.		X	
GAS		X	
EASEMENTS		X	
CONTROL CENTER		X	
RAILWAY		X	
CATV		X	

CONTACT	NAME	PHONE NUMBER	E-MAIL ADDRESS
DESIGN	IAN MCCALLUM	204-470-3154	imccallum@hydro.mb.ca
DESIGN ENGINEER	MATTHEW SINGER	204-360-3201	msinger@hydro.mb.ca
PROJECT MGMT	DARIN WACH	204-360-3082	dwach@hydro.mb.ca
ESA	RYAN AUBRY	204-360-7261	raubry@hydro.mb.ca
U/G CONSTRUCTION	BRENT KROEKER	204-793-1670	bckroeker@hydro.mb.ca
O/H CONSTRUCTION	BRYAN SANGSTER	204-360-5786	bsangster@hydro.mb.ca
HYDRO GAS			
SHAW			
MTS			
ENG TECH	PHIL BRUCE	431-373-0496	pbruce@hydro.mb.ca
ENG TECH	TOM HUMBLE	204-360-7451	thumble@hydro.mb.ca

CONTACT "CLICK BEFORE YOU DIG MANITOBA" AT

ClickBeforeYouDigMB.com

THREE FULL WORKING DAYS

PRIOR TO CONSTRUCTION FOR LOCATION OF EXISTING WATER, WASTEWATER, LAND DRAINAGE UTILITIES AND MANITOBA HYDRO UTILITIES

FOR CLEARANCE OF EXISTING WATER & WASTE DEPARTMENT PLANT CONTACT THE SURVEY & INSPECTION BRANCH 48 HOURS PRIOR TO CONSTRUCTION AT 986-3322

NOTE: INDICATION OF ALL UNDERGROUND UTILITIES IS FOR ILLUSTRATIVE PURPOSES ONLY. CONTACT THE APPLICABLE UTILITIES FOR SPECIFIC PLANT LOCATIONS AND CLEARANCES.

THIS IS A PRINT OF A DOCUMENT THAT HAS BEEN ELECTRONICALLY AUTHENTICATED WITH TECHNOLOGY AUTHORIZED BY THE EGM. THE ORIGINAL IS IN ELECTRONIC FORM.

NORTH

	DATE	REVISIONS	BY	CKD.	APP.
00					

DRAWING NUMBER	REFERENCE DRAWINGS
	UGS APPROVAL

DRAWN: IM
CHECK:
SCALE: 1:500
DATE: 2021 12 22

AREA NUMBER: 502
STATION NUMBER: 1505
FEEDER NUMBER: 503, 512, 510N22
SYSTEM VOLTAGE: 4 KV

MANITOBA HYDRO
DISTRIBUTION PLANNING & DESIGN
WO# P:32943 NETWORK # 4306080

CSC: CITY CENTRE
CUSTOMER SERVICE PROJECT
NEW ROADWAY LIGHTING
STAFFORD ST BETWEEN
CORYDON AVE AND PEMBINA HWY

1-04707-DE-50000-STAFFORD | SHT. 1/3 | REV. 00

B1 SIZE : 1000 x 707

FOR MICROFILM USE ONLY





NOTES :

CONSTRUCTION STANDARDS

TO BE CONSTRUCTED IN ACCORDANCE WITH MANITOBA HYDRO DISTRIBUTION AND SUBTRANSMISSION STANDARDS, LATEST REVISION. NO MAJOR CHANGE SHALL BE MADE WITHOUT APPROVAL OF THE DESIGN ENGINEER OR DELEGATE.

SURVEYS TO STAKE OUT SURVEY MONUMENTS, IF IN THE VICINITY OF THE NEW CONSTRUCTION TO PREVENT DAMAGE OR LOSS.

INSTALLED			
Quantity	Fixture Type	Wattage	Pole Type
0	LED	40	EXCLUSIVE
0	LED	150	EXCLUSIVE
0	LED	240	EXCLUSIVE
0	LED	240	SHARED

SALVAGED			
Quantity	Fixture Type	Wattage	Pole Type
0	LED	150	EXCLUSIVE
0	LED	150	SHARED
0	LED	240	EXCLUSIVE

LOCATION	LUMINAIRE	TYPE	MOUNTING HEIGHT	AVG LUX	U.R. RATIO AVG/MIN	U.R. RATIO MAX/MIN	MAX SPACING

PRELIMINARY
NOT TO BE USED FOR CONSTRUCTION

REEL NUMBER	MANUFACTURER	MANUFACTURE DATE

AUTHORITY	NOTIFIED	NOT REQ'D	OBTAINED
DEPT. OF HIGHWAYS		X	
MUNICIPAL		X	
M.T.S.		X	
GAS		X	
EASEMENTS		X	
CONTROL CENTER		X	
RAILWAY		X	
CATV		X	

CONTACT	NAME	PHONE NUMBER	E-MAIL ADDRESS
DESIGN	IAN MCCALLUM	204-470-3154	imccallum@hydro.mb.ca
DESIGN ENGINEER	MATTHEW SINGER	204-360-3201	msinger@hydro.mb.ca
PROJECT MGMT	DARIN WACH	204-360-3082	dwach@hydro.mb.ca
ESA	RYAN AUBRY	204-360-7261	raubry@hydro.mb.ca
U/G CONSTRUCTION	BRENT KROEKER	204-793-1670	bckroeker@hydro.mb.ca
O/H CONSTRUCTION	BRYAN SANGSTER	204-360-5786	bsangster@hydro.mb.ca
HYDRO GAS			
SHAW			
MTS			
ENG TECH	PHIL BRUCE	431-373-0496	pbruce@hydro.mb.ca
ENG TECH	TOM HUMBLE	204-360-7451	thumble@hydro.mb.ca

CONTACT "CLICK BEFORE YOU DIG MANITOBA" AT
ClickBeforeYouDigMB.com
THREE FULL WORKING DAYS
PRIOR TO CONSTRUCTION FOR LOCATION OF EXISTING WATER, WASTEWATER, LAND DRAINAGE UTILITIES AND MANITOBA HYDRO UTILITIES

FOR CLEARANCE OF EXISTING WATER & WASTE DEPARTMENT PLANT CONTACT THE SURVEY & INSPECTION BRANCH 48 HOURS PRIOR TO CONSTRUCTION AT 986-3322

NOTE: INDICATION OF ALL UNDERGROUND UTILITIES IS FOR ILLUSTRATIVE PURPOSES ONLY. CONTACT THE APPLICABLE UTILITIES FOR SPECIFIC PLANT LOCATIONS AND CLEARANCES.

THIS IS A PRINT OF A DOCUMENT THAT HAS BEEN ELECTRONICALLY AUTHENTICATED WITH TECHNOLOGY AUTHORIZED BY THE EGM. THE ORIGINAL IS IN ELECTRONIC FORM.

NORTH

	DATE	REVISIONS	BY	CKD.	APP.
00					

DRAWING NUMBER	REFERENCE DRAWINGS
	UGS APPROVAL

DRAWN: IM
CHECK:
SCALE: 1:500
DATE: 2021 12 22

AREA NUMBER: 502
STATION NUMBER: 1505
FEEDER NUMBER: 503, 512, 510N22
SYSTEM VOLTAGE: 4 KV

MANITOBA HYDRO
DISTRIBUTION PLANNING & DESIGN
WO# P:32943 NETWORK # 4306080

CSC: CITY CENTRE
CUSTOMER SERVICE PROJECT
NEW ROADWAY LIGHTING
STAFFORD ST BETWEEN
CORYDON AVE AND PEMBINA HWY

1-04707-DE-50000-STAFFORD | SHT. 2/3 | REV. 00

B1 SIZE : 1000 x 707

FOR MICROFILM USE ONLY





NOTES :

CONSTRUCTION STANDARDS

TO BE CONSTRUCTED IN ACCORDANCE WITH MANITOBA HYDRO DISTRIBUTION AND SUBTRANSMISSION STANDARDS, LATEST REVISION. NO MAJOR CHANGE SHALL BE MADE WITHOUT APPROVAL OF THE DESIGN ENGINEER OR DELEGATE.

SURVEYS TO STAKE OUT SURVEY MONUMENTS, IF IN THE VICINITY OF THE NEW CONSTRUCTION TO PREVENT DAMAGE OR LOSS.

INSTALLED			
Quantity	Fixture Type	Wattage	Pole Type
0	LED	40	EXCLUSIVE
0	LED	150	EXCLUSIVE
0	LED	240	EXCLUSIVE
0	LED	240	SHARED

SALVAGED			
Quantity	Fixture Type	Wattage	Pole Type
0	LED	150	EXCLUSIVE
0	LED	150	SHARED
0	LED	240	EXCLUSIVE

LOCATION	LUMINAIRE	TYPE	MOUNTING HEIGHT	AVG LUX	U.R. RATIO AVG:MIN	U.R. RATIO MAX:MIN	MAX SPACING

PRELIMINARY
NOT TO BE USED FOR CONSTRUCTION

REEL NUMBER	MANUFACTURER	MANUFACTURE DATE

AUTHORITY	NOTIFIED	NOT REQ'D	OBTAINED
DEPT. OF HIGHWAYS		X	
MUNICIPAL		X	
M.T.S.		X	
GAS		X	
EASEMENTS		X	
CONTROL CENTER		X	
RAILWAY		X	
CATV		X	

CONTACT	NAME	PHONE NUMBER	E-MAIL ADDRESS
DESIGN	IAN MCCALLUM	204-470-3154	imccallum@hydro.mb.ca
DESIGN ENGINEER	MATTHEW SINGER	204-360-3201	msinger@hydro.mb.ca
PROJECT MGMT	DARIN WACH	204-360-3082	dwach@hydro.mb.ca
ESA	RYAN AUBRY	204-360-7261	raubry@hydro.mb.ca
U/G CONSTRUCTION	BRENT KRIEKER	204-793-1670	bkrioeker@hydro.mb.ca
O/H CONSTRUCTION	BRYAN SANGSTER	204-360-5786	bsangster@hydro.mb.ca
HYDRO GAS			
SHAW			
MTS			
ENG TECH	PHIL BRUCE	431-373-0496	pbruce@hydro.mb.ca
ENG TECH	TOM HUMBLE	204-360-7451	thumble@hydro.mb.ca

CONTACT "CLICK BEFORE YOU DIG MANITOBA" AT

ClickBeforeYouDigMB.com

THREE FULL WORKING DAYS

PRIOR TO CONSTRUCTION FOR LOCATION OF EXISTING WATER, WASTEWATER, LAND DRAINAGE UTILITIES AND MANITOBA HYDRO UTILITIES

FOR CLEARANCE OF EXISTING WATER & WASTE DEPARTMENT PLANT CONTACT THE SURVEY & INSPECTION BRANCH 48 HOURS PRIOR TO CONSTRUCTION AT 986-3322

NOTE: INDICATION OF ALL UNDERGROUND UTILITIES IS FOR ILLUSTRATIVE PURPOSES ONLY. CONTACT THE APPLICABLE UTILITIES FOR SPECIFIC PLANT LOCATIONS AND CLEARANCES.

THIS IS A PRINT OF A DOCUMENT THAT HAS BEEN ELECTRONICALLY AUTHENTICATED WITH TECHNOLOGY AUTHORIZED BY THE EGM. THE ORIGINAL IS IN ELECTRONIC FORM.

NORTH

	DATE	REVISIONS	BY	CKD.	APP.
00					

DRAWING NUMBER	REFERENCE DRAWINGS
	UGS APPROVAL

DRAWN: IM
CHECK:
SCALE: 1:500
DATE: 2021 12 22

AREA NUMBER: 502
STATION NUMBER: 1505
FEEDER NUMBER: 503, 512, 510N22
SYSTEM VOLTAGE: 4 KV

MANITOBA HYDRO
DISTRIBUTION PLANNING & DESIGN
WO# P:32943 NETWORK # 4306080

CSC: CITY CENTRE
CUSTOMER SERVICE PROJECT
NEW ROADWAY LIGHTING
STAFFORD ST BETWEEN
CORYDON AVE AND PEMBINA HWY

1-04707-DE-50000-STAFFORD | SHT. 3/3 | REV. 00

B1 SIZE : 1000 x 707

FOR MICROFILM USE ONLY