



425-2021 ADDENDUM 1

SUPPLY AND DELIVERY OF FIREFIGHTING HOSES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: September 10, 2021
BY: Brad Enders
TELEPHONE NO. 204 390-6021

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART E – SPECIFICATIONS

- | | | |
|---------|------------------|---|
| Revise: | E3.1(a) to read: | Be constructed as follows : |
| Add: | E3.1(a)(i) | 44 mm hoses shall be made of top-quality synthetic cloth fabric. |
| Add: | E3.1(a)(ii) | 66 mm and 100 mm hoses shall be made of rubber. |
| Revise: | E8.1 to read: | Firefighting hoses shall meet or exceed NFPA 1961 Standards . |
| Add: | E8.2 | Firefighting hoses shall be ULC certified. |
| Add: | E8.2(a) | Firefighting hoses shall contain a stamp on the hose to identify ULC certification. |