



340-2022B ADDENDUM 4

INTERIOR RENOVATION OF BONIVITAL POOL RENEWAL

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: July 12, 2022
BY: Janelle Fillion, LMAG
TELEPHONE NO. 204 944-9292

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, July 19, 2022.

PART E – SPECIFICATIONS

Section 09 06 00.13 Room Finish Schedule

Revise: Remark 11 to read: Install cove base up to bank of lockers. Cove base is not required behind lockers.

Revise: Remark 14 to read: Tile floor finish to extend beneath wood cedar bench and tie into existing tiled supply bench. Refer to Drawing A7.4 for floor finish pattern. Cove tile bases to be applied on all walls, inclusive of unexposed areas beneath cedar benches.

Revise: Remark 16 to read: Tile base CT-9 is to be applied on walls where floor tile CT-7 is installed. Tile base CT-4 is to be applied where floor tile CT-5 and CT-6 are installed. Refer to Drawing A7.3 and A7.4 for floor finish pattern. Confirm final Tile base locations with Contract Administrator.

Revise: Base Material for Room 1:10 to read: CT9

Section 09 31 00 Tiling

Revise: 2.1.1.4 to read: CT-4: Daltile, Keystone Colour Through Body Porcelain, 1" x 1" mosaic, matte finish, allow for up to one (3) colours incorporated in a custom random pattern – dark tone, complete-with matching Coved Porcelain Tile.

Section 26 50 00 Lighting

Add: 2.1.2 to read: Acceptable equals:
.1 Type B2 - Signify Canada Ltd. - 2SBP3040L8CS-2-UN3-DIM
.2 Type C Type - Kenall Lighting HSEDO-14-90L40K-DCC-DV-5F-2H- SYM
.3 Type D4 - 3G Lighting - 3G-4RLI-H90-40K-UNV-DIM-GCX-FL-S4
.4 Type D8 - 3G Lighting - 3G-4RLI-H90-40K-UNV-DIM-GCX-FL-S8
.5 Type F - Signify Canada Ltd. S7R840K10WH
.6 Type E7 - Emergi-Lite - ES3WU

- .7 Type BU-1 - Emergi-Lite 12ESLXXX/2XX
- .8 Type \$D (Dimmer) – Leviton - OSSMT-MDW
- .9 Type OS (Occupancy Sensor) – Leviton - ODC04-IDW

DRAWINGS

Replace: 340-2022B _Drawing_A8.2-R0 with 340-2022B_Addendum_4 Drawing A8.2-R1.

QUESTIONS AND ANSWERS

Q1: Will Requests for Equals be considered for the Outdoor HVAC Package, Air Handling Unit-1?

A1: No equals or alternates will be considered for the Outdoor HVAC Package, AHU-1.