

Part 1 General

1.1 REFERENCE STANDARDS

- .1 American National Standard Institute (ANSI)/American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE)
 - .1 ANSI/ASHRAE 52.2-12, Method of Testing General Ventilation Air-Cleaning Devices for Removal Efficiency by Particulate Size (ANSI approved).
- .2 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-115.10-M90, Disposable Air Filters for the Removal of Particulate Matter from Ventilating Systems.
 - .2 CAN/CGSB-115.11-M85, Filters, Air, High Efficiency, Disposable, Bag Type.
 - .3 CAN/CGSB-115.12-M85, Filters, Air, Medium Efficiency, Disposable, Bag Type.
 - .4 CAN/CGSB-115.13-85, Filter Media, Automatic Roll.
 - .5 CAN/CGSB-115.14-M91, High Efficiency Cartridge Type Supported Air Filters for the Removal of Particulate Matter from Ventilating Systems.
 - .6 CAN/CGSB-115.15-M91, High Efficiency Rigid Type Air Filters for Removal of Particulate Matter from Ventilating Systems.
 - .7 CAN/CGSB-115.16-M82, Activated Carbon for Odor Removal from Ventilating Systems.
 - .8 CAN/CGSB-115.18-M85, Filter, Air, Extended Area Panel Type, Medium Efficiency.
 - .9 CAN/CGSB-115.20-95, Polarized Media Air Filter.
- .3 International Organization of Standardization (ISO)
 - .1 ISO 14644-1-99, Clean Rooms and Associated Controlled Environments - Part 1: Classification of Air Cleanliness.
- .4 Underwriters' Laboratories of Canada (ULC)
 - .1 ULC -S111-07, Standard Method of Fire Tests for Air Filter Units.
- .5 US Department of Defense - Test Method Standard
 - .1 MIL-STG-282-95, Filter Units, Protective Clothing, Gas-Mask Components and Related Products; Performance Test Methods.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for HVAC filters and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Shop Drawings:
 - .1 Submit drawings stamped and signed by professional engineer registered or licensed in Manitoba, Canada.

- .4 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.

1.3 MAINTENANCE MATERIAL SUBMITTALS

- .1 Extra Materials:
 - .1 Provide maintenance materials in accordance with Section 01 78 00 - Closeout Submittals.
 - .2 Furnish list of individual manufacturer's recommended spare parts for equipment such as frames and filters, addresses of suppliers, list of specialized tools necessary for adjusting, repairing or replacing for inclusion in operating manual.
 - .3 Spare filters: in addition to filters installed immediately prior to acceptance by City, supply 1 complete set of filters for each.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials in dry location off ground and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect HVAC filters from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.

Part 2 Products

2.1 GENERAL

- .1 Media: suitable for air at 100% RH and air temperatures between -40 and 50 degrees C.
- .2 Number of units, size and thickness of panels, overall dimensions of filter bank, configuration and capacities: as indicated.
- .3 Pressure drop when clean and dirty, sizes and thickness: as indicated on schedule.

2.2 ACCESSORIES

- .1 Holding frames: permanent channel section "T" section construction of extruded aluminum same material as casing / hood galvanized steel, 1.6 mm thick, except where specified.
- .2 Seals: to ensure leakproof operation.
- .3 Blank-off plates: as required, to fit all openings and of same material as holding frames.
- .4 Access and servicing: and/or through doors/panels on each side from upstram, downstream face of filter bank..

2.3 FIBROUS GLASS PANEL FILTERS

- .1 Disposable fibrous glass media: to CAN/CGSB-115.10 with adhesive.

- .2 Holding frame: 1.2 mm minimum thick galvanized steel with 3 mm diameter hinged wire mesh screen.
- .3 Performance: to ANSI/ASHRAE 52.2 minimum average synthetic dust weight arrestance 70 %.
- .4 Fire rated: to ULC -S111.

2.4 COTTON PANEL FILTERS

- .1 Disposable pleated reinforced cotton dry media: to CAN/CGSB 115.18.
- .2 Holding frame: galvanized steel, or slide in channel for side access.
- .3 Performance:
 - .1 Average atmospheric dust spot efficiency 30 % to ANSI/ASHRAE 52.2.
 - .2 Average synthetic dust weight arrestance 90 % to ANSI/ASHRAE 52.2.
- .4 Fire Rated: to ULC -S111.

Part 3 Execution

3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for filter installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

3.2 INSTALLATION GENERAL

- .1 Install in accordance with manufacturer's recommendations and with adequate space for access, maintenance and replacement.

3.3 ACTIVATED CARBON TYPE FILTERS

- .1 During testing, adjusting and balancing, install substitute media.
- .2 Install permanent media only after painting is completed.

3.4 REPLACEMENT MEDIA

- .1 Replace media with new upon acceptance.
- .2 Filter media new and clean, as indicated by pressure gauge, at time of acceptance.

3.5 FILTER GAUGES

- .1 Install type as indicated across each filter bank (pre-filter and final filter) in approved and easy readable location.
- .2 Mark each filter gauge with value of pressure drop for clean condition and manufacturer's recommended replacement (dirty) value.

3.6 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 00 - Cleaning.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 00 - Cleaning.
- .3 Waste Management: separate waste materials for recycling in accordance with Section 01 74 19 - Waste Management and Disposal.
 - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

END OF SECTION