



# 672-2022 ADDENDUM 1

## CONSTRUCTION OF WTP SITE FLOOD PROTECTION UPGRADES

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
BID/PROPOSAL**

ISSUED: September 29, 2022  
BY: Mike Gaudreau  
TELEPHONE NO. 204 986-8384

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID/PROPOSAL AND SHALL FORM  
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

### **FORM B: PRICES**

Replace: 672-2022\_Form\_B-Prices with 672-2022\_Addendum\_1-Form\_B-Prices. The following is a summary of changes incorporated in the replacement Bid/Proposal Submission:

Form B(R1): Revise Item No. 6.(d).

### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, October 5, 2022.

### **PART E – SPECIFICATIONS**

Revise: E8.2(f)(iv) to read: Placement of geotextile/class A geogrid as shown on the Drawings and as per CW 3135.

Revise: E8.3(f)(iv) to read: Supply and installation of geotextile/class A geogrid will be measured on an area basis and paid for at the Contract Unit Price per square metre for "Geotextile/Class A Geogrid Composite". The area to be paid for will be the total number of square metres of geotextile/class A geogrid supplied and installed in accordance with CW 3135.

Revise: E11.3.6(b) to read: Approved Products: Tideflex, Cla-Val, Proco ProFlex or approved equal in accordance with B7.

Add: E11.3.6(c) The Proco Proflex 790 inline style rubber check valves is approved as an alternate to the slip on duckbill valve.

### **APPENDICES**

Replace: 672-2022\_Appendix\_B with 672-2022\_Addendum\_1-Appendix\_B.