GENERAL NOTES:

1. ALL 120VAC POWER WIRING TO BE A MINIMUM OF #12AWG UNLESS OTHERWISE INDICATED,
2. ALL 12VDC POWER WIRING TO BE A MINIMUM OF #14AWG UNLESS OTHERWISE INDICATED,

NO.	DRAWING NUMBER	REFERENCE DRAWING TITLE
10	–	–
9	–	–
8	–	–
7	–	–
6	–	–
5	–	–
4	–	–
3	–	–
2	–	–
1	1-0162L-A0018-001	AUTOMATION PANEL LAYOUT & BILL OF MATERIALS HVAC VENTILATION PANEL JBA-L83

REFERENCE DRAWINGS

ENGINEERS GEOSCIENTISTS MANITOBA
Certificate of Authorization
KGS Group
No. 245

B.M.
ELEV.

NO.	REVISIONS	DATE (YYYY-MM-DD)	BY
0	ISSUED FOR CONSTRUCTION	2023 03 24	DDW

KGS GROUP

DESIGNED BY: A. NIRMAL
CHECKED BY: DDW
DRAWN BY: R. GASPAR
APPROVED BY: DDW
SCALE: HORIZONTAL NTS, VERTICAL NTS
RELEASED FOR CONSTRUCTION
DATE: 2022/08/24
DATE
PLOT DATE: 2023 03 23

ENGINEER'S SEAL
PROVINCE OF MANITOBA
D. WILSON
Member
22552
2023-03-23
REGISTERED PROFESSIONAL ENGINEER

CONSULTANT DRAWING NUMBER
22-0107-004-A19.01

BID OPPORTUNITY: 864-2022

Winnipeg

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENGINEERING DIVISION

METCALFE LIFT PUMPING STATION
2022 UPGRADES
AUTOMATION

POWER DISTRIBUTION SCHEMATIC
HVAC VENTILATION PANEL JBA-L83

CITY DRAWING NUMBER: 1-0162L-A0019-001
SHEET 24 OF 109

FILE PATH: P:\Projects\2022\22-0107-004\Dwg\Elec\
FILE NAME: 1-0162L-A0019-001.dwg