B SIZE – 279mm x 432mm

SETTINGS:

UNBALANCE = 10%
LINE VOLTAGE = 600
TRIP DELAY = 1sec
RESTART DELAY = 0.6sec

SHEET 27 OF 109

NOTES

1. –

ENGINEERS GEOSCIENTISTS MANITOBA
Certificate of Authorization
KGS Group
No. 245

NO.	REVISIONS	DATE	DESIGN	CHECK
0	ISSUED FOR CONSTRUCTION	2023 03 24	CSR	DDW

KGS GROUP

DESIGNED BY: A. NIRMAL
CHECKED BY: DDW
DRAWN BY: R. GASPAR
APPROVED BY: DDW
SCALE: NTS
DATE: 2022/07/15
ISSUED FOR CONSTRUCTION
BY:
DATE:
CONSULTANT NO.: 22–0107–004–A22.01

ENGINEER'S SEAL
PROVINCE OF MANITOBA
D.D. WILSON
Member
22552
2023-03-23
REGISTERED PROFESSIONAL ENGINEER

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENGINEERING DIVISION

METCALFE LIFT PUMPING STATION
2022 UPGRADES
LOOP DIAGRAM
MCC–L71 600V POWER STATUS
ESL–L712

CITY DRAWING NUMBER	SHEET	REV.	SIZE
1–0162L–A0022	001	0	B

LAST SAVE: 2023/03/23 – 8:28am
PATH: P:\Projects\2022\22–0107–004\Dwg\Elec\1–0162L–A0022–001.dwg

PLOT DATE: Mar 23, 2023 – 8:28am
BID OPPORTUNITY: 864–2022
FILE PATH: P:\Projects\2022\22–0107–004\Dwg\Elec\
FILE NAME: 1–0162L–A0022–001.dwg