NOTES

1. ISOLATE AND TAPE BACK SHIELD AT THIS END ONLY.
2. PROVIDE AND INSTALL NEW NEMA TYPE 4 JUNCTION BOX, COMPLETE WITH TERMINALS, AND IDENTIFICATION LAMACOID.

ENGINEERS GEOSCIENTISTS MANITOBA
Certificate of Authorization
KGS Group
No. 245

KGS GROUP

NO.	REVISIONS	DATE	DESIGN	CHECK
0	ISSUED FOR CONSTRUCTION	2023 03 24	CSR	DDW

DESIGNED BY: A. NIRMAL	CHECKED BY: DDW
DRAWN BY: R. GASPAR	APPROVED BY: DDW
SCALE: NTS	DATE: 2022 08 26
ISSUED FOR CONSTRUCTION BY:	DATE:
CONSULTANT NO.: 22–0107–004–A30.01	

ENGINEER'S SEAL
PROVINCE OF MANITOBA
D.D. WILSON
Member
22552
2023-03-23
REGISTERED PROFESSIONAL ENGINEER

Winnipeg
THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENGINEERING DIVISION

METCALFE LIFT PUMPING STATION
2022 UPGRADES
LOOP DIAGRAM
HVAC DAMPERS AND SUPPLY FAN
FV–L641, FV–L642, & FV–L651

CITY DRAWING NUMBER	SHEET	REV.	SIZE
1–0162L–A0030	001	0	B

B SIZE – 279mm x 432mm

LAST SAVE: 2023/03/23 – 8:29am
PATH: P:\Projects\2022\22–0107–004\Dwg\Elec\1–0162L–A0030–001.dwg

PLOT DATE: Mar 23, 2023 – 8:29am
BID OPPORTUNITY: 864–2022
FILE PATH: P:\Projects\2022\22–0107–004\Dwg\Elec\
FILE NAME: 1–0162L–A0030–001.dwg