B SIZE – 279mm x 432mm

SHEET 29 OF 109

NOTES

1. HIGH TEMPERATURE SWITCH CONTACT TO BE CLOSED WHEN MOTOR TEMPERATURE IS NORMAL AND OPEN WHEN MOTOR TEMPERATURE IS HIGH.
2. MOTOR TEMPERATURE SWITCHES ARE FOR ALARMING PURPOSES ONLY AND DO NOT LOCKOUT A LIFT PUMP.

ENGINEERS GEOSCIENTISTS MANITOBA
Certificate of Authorization
KGS Group
No. 245

NO.	REVISIONS	DATE	DESIGN	CHECK
0	ISSUED FOR CONSTRUCTION	2023 03 24	CSR	DDW

KGS GROUP

DESIGNED BY: A. NIRMAL
CHECKED BY: DDW
DRAWN BY: R. GASPAR
APPROVED BY: DDW
SCALE: NTS
DATE: 2022/07/15
ISSUED FOR CONSTRUCTION
BY: DATE:
CONSULTANT NO.: 22–0107–004–A24.01

ENGINEER'S SEAL
PROVINCE OF MANITOBA
D.D. WILSON
Member
22552
2023-03-23
REGISTERED PROFESSIONAL ENGINEER

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENGINEERING DIVISION

METCALFE LIFT PUMPING STATION 2022 UPGRADES LOOP DIAGRAM PUMP P–L01, P–L02 & P–L03 MOTOR HIGH TEMPERATURE SWITCHES TSH–L011, TSH–L021 & TSH–L031

CITY DRAWING NUMBER	SHEET	REV.	SIZE
1–0162L–A0024	001	0	B

LAST SAVE: 2023/03/23 – 8:28am
PATH: P:\Projects\2022\22–0107–004\Dwg\Elec\1–0162L–A0024–001.dwg

PLOT DATE: Mar 23, 2023 – 8:28am
BID OPPORTUNITY: 864–2022
FILE PATH: P:\Projects\2022\22–0107–004\Dwg\Elec\
FILE NAME: 1–0162L–A0024–001.dwg