



## 876-2022 ADDENDUM 1

### ROOF REPLACEMENT TURTLE ISLAND NEIGHBORHOOD CENTER 510 KING ST

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID/PROPOSAL**

ISSUED: March 3, 2023  
BY: David Firth  
TELEPHONE NO. 204 451-4098

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID/PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

---

#### **PART D – SUPPLEMENTAL CONDITIONS**

Revise: D13.2(f) to read: The bidders will provide documentation for their application to Efficiency Manitoba's Commercial Building Envelope Rebate Program for this project on behalf of the City of Winnipeg. The average R-Value shall be increased as defined in Drawing 876-2022 R-1 to meet minimum R-40.

#### **DRAWINGS**

Replace: 876-2022 \_Drawing\_R-1 with 876-2022 \_Addendum\_1 Drawing R-2