



619-2023 ADDENDUM 1

TREE REMOVAL SERVICES CENTREPORT SOUTH REGIONAL WATER AND WASTEWATER SERVICING

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: August 16, 2023
BY: Greg Heinrichs
TELEPHONE NO. 204-986-1209

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

QUESTIONS AND ANSWERS

Q1: Is the Summit Road Landfill permitted as an alternative disposal site to Brady Landfill?

A1: Yes, all trees and cuttings including Elm trees may be disposed of at the Summit Road Landfill. The Contractor must notify Brock Bradford at 204-986-7707 a minimum 5 business days prior to hauling trees to the landfill.

If the Summit Road Landfill is used by the Contractor for disposing of trees under this Contract, the Contractor will be responsible to pay all tipping fees.

Q2: If the existing berm is removed to improve site access, does it need to be replaced?

A2: No, if the existing berm on the backslope of the Sturgeon Access ditch is totally or partially removed at the designated approach location, any material excavated from the berm shall be neatly stockpiled on top of or on the north side of the berm at a maximum 3:1 slope.