

## Information Bulletin

---

# Smoke Alarm Installations in Dwelling Units

We are reminding contractors that smoke alarms in dwelling units must provide adequate coverage of each storey. When a storey has more than one level, especially when there is a change in ceiling elevation, additional smoke alarms may be required. An entry level foyer that contains an additional use such as laundry and/or storage room, for example, will likely require a smoke alarm.