



Derek Clarke, Drinking Water Officer  
Office of Drinking Water, Manitoba Sustainable Development  
Box 6000  
Gimli, MB R0C 1B0

April 2, 2020

**RE: CORRECTIVE ACTION REPORT FOR WINNIPEG PUBLIC WATER SYSTEM, 252.00**

**Incident No:** CAR-03-2020-WMR

**Reported to ODW:** March 23, 2020

**Reported by:** Louis Rivard, Superintendent of Water Distribution

**Approved by:** Zeljko Bodiroga, Water Distribution Engineer

**Incident Date:** March 21, 2020

**Incident Location:** Winnipeg 3-Dist (WM Repair)

**Incident Type:**

1. Low Positive Total Coliform (<10 per100mL), 3 MR 41/2007

**Description of Corrective Actions:**

Water Services:

Immediately made contact with ODW and Environmental Standards, flushed the isolated area and re-sampled original location. Tested the original location for bacteria, turbidity, and free chlorine until two consecutive negative bacteria results were obtained.

**Test Results:** See attached

**LIMS Reference No:** n/a

**EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING**

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports



Water and Waste Department • Service des eaux et des déchets

Sample Name	Sample Number	Date Sampled	E Coli (MPNU/100mL)	Total Coliform (MPNU/100mL)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Turbidity-field (ntu)	Temperature (°C)	Time Sampled (hrs)
Hydrant - Water Main Repair	N/A	21-Mar-20	0	5	NA	NA	NA	NA	15:20
Hydrant - Water Main Repair	219142	23-Mar-20	0	0	0.76	0.96	0.68	3.0	13:00
Hydrant - Water Main Repair	219143	24-Mar-20	0	0	0.49	0.83	0.69	2.4	13:51

NOTES/COMMENTS:

1. All microbiological tests performed by contract laboratory.
2. NR-No Result due to laboratory/analyst error.
3. NA-Not Analyzed.