



Derek Clarke, Drinking Water Officer  
Office of Drinking Water, Manitoba Sustainable Development  
Box 6000  
Gimli, MB R0C 1B0

August 24, 2020

**RE: CORRECTIVE ACTION REPORT FOR WINNIPEG PUBLIC WATER SYSTEM, 252.00**

**Incident No:** CAR-11-2020-WTP

**Reported to ODW:** July 17, 2020, 16:00

**Reported by:** Mark Fisher, Operator

**Approved by:** Dan Merredew Water Treatment Operations Supervisor

**Incident Date:** July 17, 2020

**Incident Location:** Winnipeg 2-Treated (WTP)

**Incident Type: (choose all that apply)**

Water Entering Distribution System Exceeds Turbidity Standard, 6(1) MR 41/2007

**Description of Corrective Actions:**

Filter #3 ran to 2.13 NTU at 11:32, and was over 1.00 NTU from 11:32:14 to 11:33:38, as the instrument was under maintenance.

**Test Results:** Grab samples before and after maintenance were, 0.14 NTU and 0.15 NTU respectively.

**Reference No:** N/A

**EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING**

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports