



Kale Black, Sr. Drinking Water Officer
Office of Drinking Water, Manitoba Sustainable Development
309 – 25 Tupper Street North
Portage La Prairie, MB R1N 3K1

December 7, 2020

RE: CORRECTIVE ACTION REPORT FOR WINNIPEG PUBLIC WATER SYSTEM, 252.00

Incident No: CAR-24-2020-ESD

Reported to ODW: November 26, 2020

Reported by: Brock Bradford, Analytical Services Branch Head (Acting)

Approved by: Brock Bradford, Analytical Services Branch Head (Acting)

Incident Date: November 25, 2020

Incident Location: Winnipeg 3-Dist (NE02)

Incident Type: Low Positive Total Coliform (<10 per100mL), 3 MR 41/2007

Description of Event and Corrective Actions:

Contacted the ODW and re-sampled original location for bacteria, turbidity, free/total chlorine, and temperature. Monitoring was terminated after two consecutive sets of re-samples taken 24 hours apart tested negative for bacteria.

Test Results: See attached

Reference No: Job_612

EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports

