



Water and Waste Department • Service des eaux et des déchets

January 4, 2016

Our File: 040-18-18-14-00

Dr. Khalida Hai-Santiago c/o Helen Browne  
300 Carlton Street (Room 4068)  
Winnipeg, Manitoba  
R3B 3M9

Dear Dr. Hai-Santiago:

**RE: CITY OF WINNIPEG FLUORIDE MONITORING DATA**

As a participant in the Provincial Water Fluoridation Program, the City of Winnipeg Water and Waste Department hereby submits the following fluoride monitoring data on analyses conducted by the Environmental Standards Division.

<u>LOCATION</u>	<u>SAMPLE NUMBER</u>	<u>DATE</u>	<u>RESULT(mg/L F)</u>
Distribution System (Composite – 39 Locations)	451955	November 2, 2015	0.57
	452625	November 9, 2015	0.64
	453269	November 16, 2015	0.63
	453926	November 23, 2015	0.68
	454738	November 30, 2015	0.71

Branch I chem feed was offline October 24<sup>th</sup> – October 29<sup>th</sup>, and Branch II chem feed was offline October 28<sup>th</sup> – October 29<sup>th</sup> to accommodate piping upgrades, causing the low fluoride result on November 2<sup>nd</sup>. If you have any questions on the foregoing, please call Ms. Nancy Crawford, Compliance Reporting Branch Head, at 204-986-4807.

Yours truly,

*Original signed by:*

Renée Grosselle  
Manager of Environmental Standards

NC/HD

cc: Tim Shanks, P.Eng. Manager of Water Services (e-mail)

N:\Compliance Reporting\Submittal Letters\2015\Fluoride\2015-11 Fluoride.doc