



Water and Waste Department • Service des eaux et des déchets

Environmental Standards Division • Division des Normes Environnementales

January 22, 2019

Our File: 040-18-18-14-00

Dr. Khalida Hai-Santiago c/o Helen Browne
300 Carlton Street (Room 4068)
Winnipeg, Manitoba
R3B 3M9

Dear Dr. Hai-Santiago:

RE: CITY OF WINNIPEG FLUORIDE MONITORING DATA

As a participant in the Provincial Water Fluoridation Program, the City of Winnipeg Water and Waste Department hereby submits the following fluoride monitoring data on analyses conducted by the Environmental Standards Division.

LOCATION	SAMPLE NUMBER	DATE	RESULT (mg/L F)
Distribution System (Composite – 39 Locations)	145169	1-Oct-18	0.66
	147553	8-Oct-18	0.69
	149249	15-Oct-18	0.71
	151325	22-Oct-18	0.67
	153341	29-Oct-18	0.69
	155328	5-Nov-18	0.68
	156843	12-Nov-18	0.68
	158887	19-Nov-18	0.65
	160983	26-Nov-18	0.67
	163002	3-Dec-18	0.66
	164774	10-Dec-18	0.64
	166524	17-Dec-18	0.63
	168311	24-Dec-18	0.69
	169545	31-Dec-18	0.67

If you have any questions on the foregoing, please call Ms. Nancy Crawford, Compliance Reporting Branch Head, at 204-986-4807.

Yours truly,

Original signed by:

Renée Grosselle
Manager of Environmental Standards

NC/HD

cc: Tim Shanks, P.Eng. Manager of Water Services (e-mail)