



Dr. Khalida Hai-Santiago c/o Helen Browne
300 Carlton Street (Room 4068)
Winnipeg, Manitoba
R3B 3M9

April 18, 2019

RE: FIRST QUARTER 2019 CITY OF WINNIPEG FLUORIDE MONITORING DATA

As a participant in the Provincial Water Fluoridation Program, the City of Winnipeg Water and Waste Department hereby submits the following fluoride monitoring data on analyses conducted by the Environmental Standards Division.

LOCATION	SAMPLE NUMBER	DATE	RESULT (mg/L F)
Distribution System (Composite – 39 Locations)	171154	7-Jan-19	0.65
	173107	14-Jan-19	0.63
	175016	21-Jan-19	0.70
	176392	28-Jan-19	0.71
	177789	4-Feb-19	0.74
	179584	11-Feb-19	0.69
	181367	19-Feb-19	0.65
	182895	25-Feb-19	0.67
	184735	4-Mar-19	0.65
	186457	11-Mar-19	0.70
	188357	18-Mar-19	0.72
	190100	25-Mar-19	0.69

If you have any questions on the foregoing, please call Ms. Nancy Crawford, Compliance Reporting Branch Head, at 204-986-4807.

Yours sincerely,

Original signed by:

R. Grosselle
Manager of Environmental Standards

Enclosures

cc: T. Shanks, P.Eng. (email)