



Dr. Khalida Hai-Santiago c/o Angela Peck
300 Carlton Street (Room 4068)
Winnipeg, Manitoba
R3B 3M9

January 19, 2021

RE: FOURTH QUARTER 2020 CITY OF WINNIPEG FLUORIDE MONITORING DATA

As a participant in the Provincial Water Fluoridation Program, the City of Winnipeg Water and Waste Department hereby submits the following fluoride monitoring data on analyses conducted by the Environmental Standards Division.

LOCATION	SAMPLE NUMBER	DATE	RESULT (MG/L F)
Distribution System (Composite – 39 Locations)	338033	5-Oct-20	0.68
	339944	13-Oct-20	0.71
	341601	19-Oct-20	0.73
	343439	26-Oct-20	0.68
	345286	2-Nov-20	0.74
	347107	9-Nov-20	0.69
	348600	16-Nov-20	0.71
	350278	23-Nov-20	0.72
	351918	30-Nov-20	0.76
	353655	7-Dec-20	0.73
	355424	14-Dec-20	0.75
	357169	21-Dec-20	0.74
	358949	28-Dec-20	0.76

If you have any questions on the foregoing, please call Ms. Nancy Crawford, Compliance Reporting Branch Head, at 204-986-4807.

Yours sincerely,

*Original signed by R. Grosselle
(Signed original available upon request)*

R. Grosselle
Manager of Environmental Standards

cc: T. Shanks, P.Eng. (email)