



Dr. Khalida Hai-Santiago c/o Angela Peck
300 Carlton Street (Room 4068)
Winnipeg, Manitoba
R3B 3M9

April 16, 2021

RE: FIRST QUARTER 2021 CITY OF WINNIPEG FLUORIDE MONITORING DATA

As a participant in the Provincial Water Fluoridation Program, the City of Winnipeg Water and Waste Department hereby submits the following fluoride monitoring data on analyses conducted by the Environmental Standards Division.

LOCATION	SAMPLE NUMBER	DATE	RESULT (MG/L F)
Distribution System (Composite – 39 Locations)	360232	4-Jan-21	0.75
	361995	11-Jan-21	0.74
	363742	18-Jan-21	0.75
	365387	25-Jan-21	0.76
	367059	1-Feb-21	0.75
	368657	8-Feb-21	0.68
	370258	16-Feb-21	0.76
	371803	22-Feb-21	0.74
	373651	1-Mar-21	0.75
	375346	8-Mar-21	0.76
	377130	15-Mar-21	0.73
	378626	22-Mar-21	0.73
	380337	29-Mar-21	0.71

If you have any questions on the foregoing, please call Ms. Nancy Crawford, Compliance Reporting Branch Head, at 204-986-4807.

Yours sincerely,

*Original signed by R. Grosselle
(Signed original available upon request)*

R. Grosselle
Manager of Environmental Standards

cc: M. Szmon, P.Eng. (email)