



Dr. Khalida Hai-Santiago c/o Angela Peck
300 Carlton Street (Room 4068)
Winnipeg, Manitoba
R3B 3M9

July 18, 2023

RE: SECOND QUARTER 2023 CITY OF WINNIPEG FLUORIDE MONITORING DATA

As a participant in the Provincial Water Fluoridation Program, the City of Winnipeg Water and Waste Department hereby submits the following fluoride monitoring data on analyses conducted by the Environmental Standards Division.

LOCATION	SAMPLE NUMBER	DATE	FLUORIDE (mg/L)
Distribution System (Composite – 39 Locations)	561697	3-Apr-23	0.31
	563521	11-Apr-23	0.29
	564888	17-Apr-23	0.27
	566685	27-Apr-23	0.31
	568222	1-May-23	0.60
	569843	8-May-23	0.59
	571530	15-May-23	0.58
	573222	23-May-23	0.61
	574761	29-May-23	0.63
	576741	5-Jun-23	0.64
	578671	12-Jun-23	0.64
	580395	19-Jun-23	0.64
	582142	26-Jun-23	0.67

nr: no result ns: no sample na: not analyzed

Comments:

The Branch 2 chemical feed line froze during planned upgrades at the Deacon Booster Pumping Station; the line was thawed and returned to normal operation on April 24, 2023.

If you have any questions on the foregoing, please call Ms. Nancy Crawford, Compliance Reporting Branch Head, at 204-986-4807.

Yours sincerely,

Original signed by R. Grosselle:

(Signed original available upon request)

Manager of Environmental Standards

cc: Manager of Water Services (email)

ENVIRONMENTAL STANDARDS DIVISION

2230 Main Street, Winnipeg, Manitoba R2V 4T8

DIVISION DES NORMES ENVIRONNEMENTALES

2230, rue Main, Winnipeg (Manitoba) R2V 4T8

T. | Tél. : 204-986-4684

F. | Fax : 204-339-2147

winnipeg.ca/waterandwaste