



Water and Waste Department • Service des eaux et des déchets

April 12, 2013

Our File: 040-18-18-14-00

Khalida Hai-Santiago c/o Helen Browne
300 Carlton Street (Room 4068)
Winnipeg, Manitoba
R3B 3M9

Dear Dr. Hai-Santiago:

RE: CITY OF WINNIPEG FLUORIDE MONITORING DATA

As a participant in the Provincial Water Fluoridation Program, the City of Winnipeg Water and Waste Department hereby submits the following fluoride monitoring data on analyses conducted by the Environmental Standards Division.

<u>LOCATION</u>	<u>SAMPLE NUMBER</u>	<u>DATE</u>	<u>RESULT(mg/L F)</u>
Distribution System (Composite – 39 Locations)	352983	March 4, 2013	0.70
	353690	March 11, 2013	0.57
	354231	March 18, 2013	0.18
	354950	March 25, 2013	0.12

On Saturday, March 9, 2013, the fluoridation system was shut down for maintenance on the chemical storage tanks which contributed to the low distribution system composite fluoride results. The fluoridation system was put back into service on March 26, 2013.

If you have any questions on the foregoing, please call Ms. Renée Grosselle, Supervisor of Compliance Reporting, at 204-986-8359.

Yours truly,

Original signed by :

K.J.T. Kjartanson, P.Eng.
Manager of Environmental Standards Division

RG/hd

cc: Terry Josephson, P.Eng. Manager of Water Services (e-mail)

N:\Compliance Reporting\Submittal Letters\2013\Dental\Dental-Mar.doc