



Water and Waste Department • Service des eaux et des déchets

---

February 29, 2016

Our File: 040-18-18-55-00

Melanie Betsill  
Office of Drinking Water  
Manitoba Conservation and Water Stewardship  
1007 Century Street  
Winnipeg, Manitoba R3H 0W4

Dear Ms. Betsill:

**RE: TOTAL TRIHALOMETHANE SUMMARY REPORT  
FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM FOR QUARTER 1 - 2016**

---

Please find attached the Total Trihalomethane Summary Report for the first quarter of 2016 for the Winnipeg water supply system for your review and records.

Please let me know of any concerns or questions respecting this submission. I may be reached at the below address, by telephone at 204-986-8359 or by e-mail at [rgrosselle@winnipeg.ca](mailto:rgrosselle@winnipeg.ca).

Thanks for your ongoing cooperation and understanding in this matter.

Yours sincerely,

*Original signed by:*

R. Grosselle  
Manager of Environmental Standards

RG/nc  
Attachments

c: Dr. L. Richards, Winnipeg Regional Health Authority  
Dr. H. Chang, Winnipeg Regional Health Authority  
Dr. S. Roberecki, Manitoba Health  
M. L. Geer, CPA, CA (e-mail)  
G. Patton, P.Eng. (e-mail)  
T. Shanks, P.Eng. (e-mail)  
C. Diduck (e-mail)

N:\Compliance Reporting\Submittal Letters\2016\ODW - THM and HAA\2016-Q1 THM Submittal Letter.doc

*Embrace the spirit • Vivez l'esprit*

Environmental Standards Division • Division des normes environnementales  
2230 Main Street • 2230, Rue Main • Winnipeg • Manitoba R2V 4T8  
tel/tél. (204) 986-4684 • fax/télec. (204) 339-2147 • [www.winnipeg.ca](http://www.winnipeg.ca)

**CITY OF WINNIPEG  
WATER AND WASTE DEPARTMENT  
ENVIRONMENTAL STANDARDS DIVISION**

**Total Trihalomethane Summary Report**

Reporting Period: Quarter 1 2016

SAMPLE DATE	DISTRIBUTION SYSTEM THM RESULTS (ug/L)					
	WC-12	WC-06	NW-05	NE-09	SE-07	SW-08
Monday, May 11, 2015	27	25	28	26	27	26
Monday, August 10, 2015	25	26	36	27	37	40
Monday, November 02, 2015	17	15	21	20	19	16
Monday, February 01, 2016	11	10	10	13	11	10
<b>RUNNING AVERAGE THM</b>	<b>20</b>	<b>19</b>	<b>24</b>	<b>22</b>	<b>24</b>	<b>23</b>

COMMENTS:

NS - NO SAMPLE  
NR - NO RESULT

Methodology

Trihalomethanes analyzed by GC-ECD, Standard Methods for the Examination of Water and Waste Water, 21<sup>st</sup> Edition, Method 6232

Report Compiled by: H.Demchenko

Approved in LIMS by: C.Diduck

File: WQR4

Date Approved: February 24, 2016

N:\Environmental Standards\Analytical Services\WQ Data\Routine Water Quality\2016\Quarterly THM\Quarterly THM 2016.xlsx\THM Q1